



Torrance County

Purchasing Department

Noah J. Sedillo

PO Box 48

205 S Ninth Street

Estancia, NM 87016

Phone: (505) 544-4730 Fax: (505) 384-5294

www.torrancecountynm.org

IFB 2023-01

ADDENDA NO. 3

January 30, 2023

Torrance County Road Department Building

Responses to questions:

Q: Walk door; is PEMB manufacturer insulated metal door sufficient?

R: Need a U-value of 0.42. PEMB metal is acceptable if it meets this requirement.